

2014 Consumer Confidence Report

Water System Name: LITTLE POTATO SLOUGH MUTUAL

Report Date: June 2015

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2014.

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo ó hable con alguien que lo entienda bien.

Type of water source(s) in use: According to CDPH records, this Source is Surface Water. This Assessment was done using the Other Methods.

Your water comes from 1 source(s): Little Potato Slough - TREATED

Opportunities for public participation in decisions that affect drinking water quality: Regularly-scheduled water board or city/county council meetings are held at the Club House Village every third Thursday of every month, at 4 O'Clock.

For more information about this report, or any questions relating to your drinking water, please call (916) 524 - 4560 and ask for Luis Ching or visit our website at www.lpswaterco.com.

TERMS USED IN THIS REPORT

Maximum Contaminant Level (MCL): The highest level of contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Primary Drinking Water Standards (PDWS): MCLs and MRDLs for the contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

Secondary Drinking Water Standards (SDWS): MCLs for the contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Regulatory Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

ppm: parts per million or milligrams per liter (mg/L)

ppb: parts per billion or micrograms per liter (µg/L)

The sources of drinking water: (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, that can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the USEPA and the California Department of Public Health (Department) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. Department regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

Tables 1, 2, 3, 4, 5, 6 and 7 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The Department allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.

Table 1 - SAMPLING RESULTS SHOWING THE DETECTION OF COLIFORM BACTERIA

Microbiological Contaminants (complete if bacteria detected)	Highest No. of Detections	No. of Months in Violation	MCL	MCLG	Typical Sources of Contaminant
Total Coliform Bacteria	1/mo. (2014)	0	no more than 1 positive monthly sample	0	Naturally present in the environment.

Table 2 - SAMPLING RESULTS SHOWING THE DETECTION OF LEAD AND COPPER

Lead and Copper (complete if lead or copper detected in last sample set)	Sample Date	90th percentile level detected	No. Sites Exceeding AL	AL	PHG	Typical Sources of Contaminant
Copper (ppm)	10 (2014)	0.03	0	1.3	.3	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

Table 3 - SAMPLING RESULTS FOR SODIUM AND HARDNESS

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Sources of Contaminant
Sodium (ppm)	(2014)	19	N/A	none	none	Salt present in the water and is generally naturally occurring
Hardness (ppm)	(2014)	66.2	N/A	none	none	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

Any violation of MCL, AL or MRDL is highlighted. Additional information regarding the violation is provided later in this report.

Table 4 - DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD						
Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Sources of Contaminant
Fluoride (ppm)	(2014)	3.9	N/A	2	1	Erosion of natural deposits; water additive that promotes strong teeth; discharge from fertilizer and aluminum factories.
Nitrate (ppm)	(2014)	3.3	N/A	45	45	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Nitrate + Nitrite as N (ppm)	(2014)	0.8	N/A	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits

Table 5 - DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD						
Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Sources of Contaminant
Chloride (ppm)	(2014)	22	N/A	500	n/a	Runoff/leaching from natural deposits; seawater influence
Iron (ppb)	(2014)	190	N/A	300	n/a	Leaching from natural deposits; Industrial wastes
Odor Threshold at 60 °C (TON)	(2014)	2	N/A	3	n/a	Naturally-occurring organic materials.
Specific Conductance (umhos/cm)	(2014)	234	N/A	1600	n/a	Substances that form ions when in water; seawater influence
Sulfate (ppm)	(2014)	24	N/A	500	n/a	Runoff/leaching from natural deposits; industrial wastes
Total Dissolved Solids (ppm)	(2014)	140	N/A	1000	n/a	Runoff/leaching from natural deposits
Turbidity (NTU)	(2014)	0.3	N/A	5	n/a	Soil runoff

Table 6 - DETECTION OF UNREGULATED CONTAMINANTS					
Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	Notification Level	Typical Sources of Contaminant
Boron (ppm)	(2014)	0.1	N/A	1	The babies of some pregnant women who drink water containing boron in excess of the notification level may have an increased risk of developmental effects, based on studies in laboratory animals.

Table 7 - DETECTION OF FEDERAL DISINFECTANT/DISINFECTANT BYPRODUCT RULE						
Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL (MRDL)	PHG (MCLG)	Typical Sources of Contaminant
Total Trihalomethanes (TTHMs) (ppb)	(2014)	58.8	49.3 - 66.9	80	n/a	By-product of drinking water disinfection
Haloacetic Acids (five) (ppb)	(2014)	48	38 - 61	60	n/a	By-product of drinking water disinfection

Any violation of MCL, AL or MRDL is highlighted. Additional information regarding the violation is provided later in this report.

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead Specific Language for Community Water Systems: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with the service lines and home plumbing. *Little Potato Slough* is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Summary Information for Violation of a MCL, MRDL, AL, TT, or Monitoring and Reporting Requirement

About our Fluoride: Some people who drink water containing fluoride in excess of the federal MCL of 4 mg/L over many years may get bone disease, including pain and tenderness of the bones. Children who drink water containing fluoride in excess of the state MCL of 2 mg/L may get mottled teeth.

About our Haloacetic Acids (five): Some people who drink water containing haloacetic acids in excess of the MCL over many years may have an increased risk of getting cancer.

2014 Consumer Confidence Report Drinking Water Assessment Information

Assessment Information

A source water assessment was conducted for the LITTLE POTATO SLOUGH - RAW of the LITTLE POTATO SLOUGH MUTUAL water system in January, 2003.

Little Potato Slough - TREATED - is considered most vulnerable to the following activities:
Gas Stations, and Animal Feeding Operations in the watershed.

Acquiring Information

A copy of the complete assessment may be viewed at:

Drinking Water Field Operations Branch
31 E. Channel Street
Room 270
Stockton, CA 95202

You may request a summary of the assessment be sent to you by contacting:

District 10 - Stockton
Vacant
31 E. Channel Street
Room 270
Stockton CA 95202
(209) 948-7696

Little Potato Slough

Analytical Results By FGL - 2014

MICROBIOLOGICAL CONTAMINANTS									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Total Coliform Bacteria			0	5%	n/a			0	-
TP-BR1- 19 Summersky	STK1452481-1					2014-12-08	Absent		
TP-BR1- 19 Summersky	STK1450925-1					2014-10-27	Absent		
TP-BR1- 19 Summersky	STK1450677-6					2014-10-16	<1.0		
TP-BR1- 19 Summersky	STK1450557-6					2014-10-13	<1.0		
TP-BR1- 19 Summersky	STK1439359-1					2014-09-15	Absent		
TP-BR1- 19 Summersky	STK1437767-1					2014-08-04	Absent		
TP-BR1- 19 Summersky	STK1437376-6					2014-07-24	<1.0		
TP-BR1- 19 Summersky	STK1436839-1					2014-07-09	<1.0		
TP-BR1- 19 Summersky	STK1436312-1					2014-06-30	Absent		
TP-BR1- 19 Summersky	STK1434699-1					2014-05-19	<1.0		
TP-BR1- 19 Summersky	STK1434557-1					2014-05-14	Absent		
TP-BR1- 19 Summersky	STK1433066-1					2014-04-07	Absent		
TP-BR1- 19 Summersky	STK1431584-1					2014-02-24	Absent		
TP-BR1- 19 Summersky	STK1430342-1					2014-01-13	Absent		
TP-BR2- 05 Riverbend	STK1452654-1					2014-12-15	Absent		
TP-BR2- 05 Riverbend	STK1451022-1					2014-11-03	Absent		
TP-BR2- 05 Riverbend	STK1450677-5					2014-10-16	<1.0		
TP-BR2- 05 Riverbend	STK1450557-5					2014-10-13	<1.0		
TP-BR2- 05 Riverbend	STK1439617-1					2014-09-22	Absent		
TP-BR2- 05 Riverbend	STK1438091-1					2014-08-13	Absent		
TP-BR2- 05 Riverbend	STK1437376-5					2014-07-24	<1.0		
TP-BR2- 05 Riverbend	STK1436839-2					2014-07-09	<1.0		
TP-BR2- 05 Riverbend	STK1436642-1					2014-07-07	Absent		
TP-BR2- 05 Riverbend	STK1435012-1					2014-05-27	Absent		
TP-BR2- 05 Riverbend	STK1434699-2					2014-05-19	<1.0		
TP-BR2- 05 Riverbend	STK1433460-1					2014-04-14	Absent		
TP-BR2- 05 Riverbend	STK1431826-1					2014-03-03	Absent		
TP-BR2- 05 Riverbend	STK1430446-1					2014-01-20	Absent		
TP-BR3- RV Space #239	STK1433887-2					2014-04-29	<1.0		
TP-BR3- RV Space #286	STK1452862-1					2014-12-22	Absent		
TP-BR3- RV Space #286	STK1451457-1					2014-11-10	Absent		
TP-BR3- RV Space #286	STK1450677-2					2014-10-16	<1.0		
TP-BR3- RV Space #286	STK1450557-2					2014-10-13	<1.0		
TP-BR3- RV Space #286	STK1439887-1					2014-09-29	Absent		
TP-BR3- RV Space #286	STK1438270-1					2014-08-18	Absent		
TP-BR3- RV Space #286	STK1437376-2					2014-07-24	<1.0		
TP-BR3- RV Space #286	STK1437030-1					2014-07-14	Absent		
TP-BR3- RV Space #286	STK1436839-3					2014-07-09	<1.0		
TP-BR3- RV Space #286	STK1435243-1					2014-06-02	Absent		
TP-BR3- RV Space #286	STK1434699-3					2014-05-19	<1.0		
TP-BR3- RV Space #286	STK1433662-1					2014-04-21	Absent		
TP-BR3- RV Space #286	STK1430751-1					2014-01-27	Absent		
TP-BR4- RV Space #228	STK1453020-1					2014-12-29	Absent		
TP-BR4- RV Space #228	STK1451685-1					2014-11-17	Absent		
TP-BR4- RV Space #228	STK1450677-3					2014-10-16	<1.0		
TP-BR4- RV Space #228	STK1450557-3					2014-10-13	<1.0		
TP-BR4- RV Space #228	STK1450163-1					2014-10-06	Absent		
TP-BR4- RV Space #228	STK1438637-1					2014-08-25	Absent		
TP-BR4- RV Space #228	STK1437376-3					2014-07-24	<1.0		
TP-BR4- RV Space #228	STK1437251-1					2014-07-21	Absent		
TP-BR4- RV Space #228	STK1436839-4					2014-07-09	<1.0		
TP-BR4- RV Space #228	STK1435570-1					2014-06-09	Absent		

TP-BR4- RV Space #228	STK1434699-4					2014-05-19	<1.0		
TP-BR4- RV Space #228	STK1433887-1					2014-04-29	<1.0		
TP-BR4- RV Space #228	STK1433778-1					2014-04-28	Present		
TP-BR4- RV Space #228	STK1432310-1					2014-03-17	Absent		
TP-BR4- RV Space #228	STK1432124-1					2014-03-10	Absent		
TP-BR4- RV Space #228	STK1430954-1					2014-02-03	Absent		
TP-BR4- RV Space #232	STK1433887-3					2014-04-29	<1.0		
TP-BR5- R+HS Betwn Shed1&2	STK1451890-1					2014-11-24	Absent		
TP-BR5- R+HS Betwn Shed1&2	STK1450677-4					2014-10-16	<1.0		
TP-BR5- R+HS Betwn Shed1&2	STK1450611-1					2014-10-15	Absent		
TP-BR5- R+HS Betwn Shed1&2	STK1450557-4					2014-10-13	<1.0		
TP-BR5- R+HS Betwn Shed1&2	STK1438882-1					2014-09-02	Absent		
TP-BR5- R+HS Betwn Shed1&2	STK1437376-4					2014-07-24	<1.0		
TP-BR5- R+HS Betwn Shed1&2	STK1436839-5					2014-07-09	<1.0		
TP-BR5- R+HS Betwn Shed1&2	STK1435841-1					2014-06-16	Absent		
TP-BR5- R+HS Betwn Shed1&2	STK1434699-6					2014-05-19	<1.0		
TP-BR5- R+HS Betwn Shed1&2	STK1432753-1					2014-03-31	Absent		
TP-BR5- R+HS Betwn Shed1&2	STK1431251-1					2014-02-10	Absent		
TP-BR6- Slip 159 (Tomato Shed)	STK1452037-1					2014-12-01	Absent		
TP-BR6- Slip 159 (Tomato Shed)	STK1450692-1					2014-10-20	Absent		
TP-BR6- Slip 159 (Tomato Shed)	STK1450677-1					2014-10-16	<1.0		
TP-BR6- Slip 159 (Tomato Shed)	STK1450557-1					2014-10-13	<1.0		
TP-BR6- Slip 159 (Tomato Shed)	STK1439230-1					2014-09-08	Absent		
TP-BR6- Slip 159 (Tomato Shed)	STK1437472-1					2014-07-28	Absent		
TP-BR6- Slip 159 (Tomato Shed)	STK1437376-1					2014-07-24	<1.0		
TP-BR6- Slip 159 (Tomato Shed)	STK1436839-6					2014-07-09	<1.0		
TP-BR6- Slip 159 (Tomato Shed)	STK1436136-1					2014-06-23	Absent		
TP-BR6- Slip 159 (Tomato Shed)	STK1434699-5					2014-05-19	<1.0		
TP-BR6- Slip 159 (Tomato Shed)	STK1434068-1					2014-05-05	Absent		
TP-BR6- Slip 159 (Tomato Shed)	STK1432497-1					2014-03-24	Absent		
TP-BR6- Slip 159 (Tomato Shed)	STK1431418-1					2014-02-17	Absent		
TP-BR6- Slip 159 (Tomato Shed)	STK1430072-1					2014-01-06	Absent		

LEAD AND COPPER RULE

		Units	MCLG	CA-MCL	PHG	Sampled	Result	90th Percentile	# Samples
Copper		ppm		1.3	.3			0.03	10
LP-CuPb- 31 River Bench Dr.	STK1439616-2	ppm				2014-09-22	ND		
LP-CuPb01- 08 Blackberry Ct.	STK1439616-1	ppm				2014-09-22	ND		
LP-CuPb03- 12 Blue Teal Ct.	STK1439616-3	ppm				2014-09-22	0.08		
LP-CuPb04- 26 Whispering Wy.	STK1439616-4	ppm				2014-09-22	ND		
LP-CuPb05- 14 Whispering Wy.	STK1439616-5	ppm				2014-09-22	ND		
LP-CuPb06- 28 Wild Rose Ct.	STK1439616-6	ppm				2014-09-22	ND		
LP-CuPb07- 24 Riverbend Dr.	STK1439616-7	ppm				2014-09-22	ND		
LP-CuPb08- 02 Riverbend Dr.	STK1439616-8	ppm				2014-09-22	ND		
LP-CuPb09- 12 Robin Ct.	STK1439616-9	ppm				2014-09-22	ND		
LP-CuPb10- 04 Silverwood Ct.	STK1439616-10	ppm				2014-09-22	ND		

SAMPLING RESULTS FOR SODIUM AND HARDNESS

		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Sodium		ppm		none	none			19	19 - 19
Little Potato Slough - TREATED	STK1451020-1	ppm				2014-11-03	19		
Hardness		ppm		none	none			66.2	66.2 - 66.2
Little Potato Slough - TREATED	STK1451020-1	ppm				2014-11-03	66.2		

PRIMARY DRINKING WATER STANDARDS (PDWS)

		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
--	--	-------	------	--------	-----	---------	--------	----------------	-----------

Fluoride		ppm		2	1			3.9	3.9 - 3.9
Little Potato Slough - TREATED	STK1451020-1	ppm				2014-11-03	3.9		
Nitrate		ppm		45	45			3.3	3.3 - 3.3
Little Potato Slough - TREATED	STK1451020-1	ppm				2014-11-03	3.3		
Nitrate + Nitrite as N		ppm		10	10			0.8	0.8 - 0.8
Little Potato Slough - TREATED	STK1451020-1	ppm				2014-11-03	0.8		

SECONDARY DRINKING WATER STANDARDS (SDWS)									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Chloride		ppm		500	n/a			22	22 - 22
Little Potato Slough - TREATED	STK1451020-1	ppm				2014-11-03	22		
Iron		ppb		300	n/a			190	190 - 190
Little Potato Slough - TREATED	STK1451020-1	ppb				2014-11-03	190		
Odor Threshold at 60 °C		TON		3	n/a			2	2 - 2
Little Potato Slough - TREATED	STK1451020-1	TON				2014-11-03	2		
Specific Conductance		umhos/cm		1600	n/a			234	234 - 234
Little Potato Slough - TREATED	STK1451020-1	umhos/cm				2014-11-03	234		
Sulfate		ppm		500	n/a			24	24 - 24
Little Potato Slough - TREATED	STK1451020-1	ppm				2014-11-03	24		
Total Dissolved Solids		ppm		1000	n/a			140	140 - 140
Little Potato Slough - TREATED	STK1451020-1	ppm				2014-11-03	140		
Turbidity		NTU		5	n/a			0.3	0.3 - 0.3
Little Potato Slough - TREATED	STK1451020-1	NTU				2014-11-03	0.3		

UNREGULATED CONTAMINANTS									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Boron		ppm		NS	n/a			0.1	0.1 - 0.1
Little Potato Slough - TREATED	STK1451020-1	ppm				2014-11-03	0.1		

DETECTION OF FEDERAL DISINFECTANT/DISINFECTANT BYPRODUCT RULE									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Total Trihalomethanes (TTHMs)		ppb		80	n/a			58.8	49.3 - 66.9
LP-ST2DBP - 17 Summersky	STK1450206-2	ppb				2014-10-06	56.4		
LP-ST2DBP - 17 Summersky	STK1436641-2	ppb				2014-07-07	62.5		
LP-ST2DBP - 17 Summersky	STK1433017-2	ppb				2014-04-07	66.9		
LP-ST2DBP - 17 Summersky	STK1430076-2	ppb				2014-01-06	49.3		
Haloacetic Acids (five)		ppb		60	n/a			48	38 - 61
LP-ST2DBP - 5 River Bend	STK1450206-1	ppb				2014-10-06	51		
LP-ST2DBP - 5 River Bend	STK1436641-1	ppb				2014-07-07	43		
LP-ST2DBP - 5 River Bend	STK1433017-1	ppb				2014-04-07	38		
LP-ST2DBP - 5 River Bend	STK1430076-1	ppb				2014-01-06	61		

Little Potato Slough

CCR Login Linkage - 2014

FGL Code	Lab ID	Date_Sampled	Method	Description	Property
J39/022- well T	STK1451020-1	2014-11-03	Wet Chemistry	Little Potato Slough - TREATED	Water Quality Monitoring
	STK1451020-1	2014-11-03	General Mineral	Little Potato Slough - TREATED	Water Quality Monitoring
31 River Bench	STK1439616-2	2014-09-22	Metals, Total	LP-CuPb- 31 River Bench Dr.	Copper & Lead Monitoring
8 Blackberry Ct	STK1439616-1	2014-09-22	Metals, Total	LP-CuPb01- 08 Blackberry Ct.	Copper & Lead Monitoring
12 Blue Teal Ct	STK1439616-3	2014-09-22	Metals, Total	LP-CuPb03- 12 Blue Teal Ct.	Copper & Lead Monitoring
26 Whispering W	STK1439616-4	2014-09-22	Metals, Total	LP-CuPb04- 26 Whispering Wy.	Copper & Lead Monitoring
14 Whispering W	STK1439616-5	2014-09-22	Metals, Total	LP-CuPb05- 14 Whispering Wy.	Copper & Lead Monitoring
28 Wild Rose Ct	STK1439616-6	2014-09-22	Metals, Total	LP-CuPb06- 28 Wild Rose Ct.	Copper & Lead Monitoring
24 Riverbend Dr	STK1439616-7	2014-09-22	Metals, Total	LP-CuPb07- 24 Riverbend Dr.	Copper & Lead Monitoring
2 Riverbend Dr.	STK1439616-8	2014-09-22	Metals, Total	LP-CuPb08- 02 Riverbend Dr.	Copper & Lead Monitoring
12 Robin Ct.	STK1439616-9	2014-09-22	Metals, Total	LP-CuPb09- 12 Robin Ct.	Copper & Lead Monitoring
4 Silverwood Ct	STK1439616-10	2014-09-22	Metals, Total	LP-CuPb10- 04 Silverwood Ct.	Copper & Lead Monitoring
DBP2 17 Summers	STK1430076-2	2014-01-06	EPA 551.1	LP-ST2DBP - 17 Summersky	Stage 2 IDSE Monitoring
	STK1433017-2	2014-04-07	EPA 551.1	LP-ST2DBP - 17 Summersky	Stage 2 IDSE Monitoring
	STK1436641-2	2014-07-07	EPA 551.1	LP-ST2DBP - 17 Summersky	Stage 2 IDSE Monitoring
	STK1450206-2	2014-10-06	EPA 551.1	LP-ST2DBP - 17 Summersky	Stage 2 IDSE Monitoring
DBP2 5 River	STK1430076-1	2014-01-06	EPA 552.2	LP-ST2DBP - 5 River Bend	Stage 2 IDSE Monitoring
	STK1433017-1	2014-04-07	EPA 552.2	LP-ST2DBP - 5 River Bend	Stage 2 IDSE Monitoring
	STK1436641-1	2014-07-07	EPA 552.2	LP-ST2DBP - 5 River Bend	Stage 2 IDSE Monitoring
	STK1450206-1	2014-10-06	EPA 552.2	LP-ST2DBP - 5 River Bend	Stage 2 IDSE Monitoring
19 Summersky	STK1430342-1	2014-01-13	Coliform	TP-BR1- 19 Summersky	Water Monitoring-Routine #1
	STK1431584-1	2014-02-24	Coliform	TP-BR1- 19 Summersky	Water Monitoring-Routine #1
	STK1433066-1	2014-04-07	Coliform	TP-BR1- 19 Summersky	Water Monitoring-Routine #1
	STK1434557-1	2014-05-14	Coliform	TP-BR1- 19 Summersky	Water Monitoring-Routine #1
	STK1434699-1	2014-05-19	Coliform	TP-BR1- 19 Summersky	Water Monitoring-Routine #1
	STK1436312-1	2014-06-30	Coliform	TP-BR1- 19 Summersky	Water Monitoring-Routine #1
	STK1436839-1	2014-07-09	Coliform	TP-BR1- 19 Summersky	Water Monitoring-Routine #1
	STK1437376-6	2014-07-24	Coliform	TP-BR1- 19 Summersky	Water Monitoring-Routine #1
	STK1437767-1	2014-08-04	Coliform	TP-BR1- 19 Summersky	Water Monitoring-Routine #1
	STK1439359-1	2014-09-15	Coliform	TP-BR1- 19 Summersky	Water Monitoring-
	STK1450557-6	2014-10-13	Coliform	TP-BR1- 19 Summersky	Water Monitoring-Routine #1
	STK1450677-6	2014-10-16	Coliform	TP-BR1- 19 Summersky	Water Monitoring-Routine #1
	STK1450925-1	2014-10-27	Coliform	TP-BR1- 19 Summersky	Water Monitoring-Routine #1
	STK1452481-1	2014-12-08	Coliform	TP-BR1- 19 Summersky	Water Monitoring
5 Riverbend	STK1430446-1	2014-01-20	Coliform	TP-BR2- 05 Riverbend	Water Monitoring-Routine #2
	STK1431826-1	2014-03-03	Coliform	TP-BR2- 05 Riverbend	Water Monitoring-Routine #2
	STK1433460-1	2014-04-14	Coliform	TP-BR2- 05 Riverbend	Water Monitoring-Routine #2
	STK1434699-2	2014-05-19	Coliform	TP-BR2- 05 Riverbend	Water Monitoring-Routine #2
	STK1435012-1	2014-05-27	Coliform	TP-BR2- 05 Riverbend	Water Monitoring-Routine #2
	STK1436642-1	2014-07-07	Coliform	TP-BR2- 05 Riverbend	Water Monitoring-Routine #2
	STK1436839-2	2014-07-09	Coliform	TP-BR2- 05 Riverbend	Water Monitoring-Routine #2
	STK1437376-5	2014-07-24	Coliform	TP-BR2- 05 Riverbend	Water Monitoring-Routine #2
	STK1438091-1	2014-08-13	Coliform	TP-BR2- 05 Riverbend	Water Monitoring-Routine #2
	STK1439617-1	2014-09-22	Coliform	TP-BR2- 05 Riverbend	Water Monitoring-Routine #2
	STK1450557-5	2014-10-13	Coliform	TP-BR2- 05 Riverbend	Water Monitoring-Routine #2
	STK1450677-5	2014-10-16	Coliform	TP-BR2- 05 Riverbend	Water Monitoring-Routine #2
	STK1451022-1	2014-11-03	Coliform	TP-BR2- 05 Riverbend	Water Monitoring-Routine #2
	STK1452654-1	2014-12-15	Coliform	TP-BR2- 05 Riverbend	Water Monitoring-Routine #2
RV Space #239	STK1433887-2	2014-04-29	Coliform	TP-BR3- RV Space #239	Water Monitoring-Routine #3
RV Space #286	STK1430751-1	2014-01-27	Coliform	TP-BR3- RV Space #286	Water Monitoring-Routine #3
	STK1433662-1	2014-04-21	Coliform	TP-BR3- RV Space #286	Water Monitoring-Routine #3
	STK1434699-3	2014-05-19	Coliform	TP-BR3- RV Space #286	Water Monitoring-Routine #3
	STK1435243-1	2014-06-02	Coliform	TP-BR3- RV Space #286	Water Monitoring-Routine #3
	STK1436839-3	2014-07-09	Coliform	TP-BR3- RV Space #286	Water Monitoring-Routine #3
	STK1437030-1	2014-07-14	Coliform	TP-BR3- RV Space #286	Water Monitoring-Routine #3

	STK1437376-2	2014-07-24	Coliform	TP-BR3- RV Space #286	Water Monitoring-Routine #3
	STK1438270-1	2014-08-18	Coliform	TP-BR3- RV Space #286	Water Monitoring-Routine #3
	STK1439887-1	2014-09-29	Coliform	TP-BR3- RV Space #286	Water Monitoring-Routine #3
	STK1450557-2	2014-10-13	Coliform	TP-BR3- RV Space #286	Water Monitoring-Routine #3
	STK1450677-2	2014-10-16	Coliform	TP-BR3- RV Space #286	Water Monitoring-Routine #3
	STK1451457-1	2014-11-10	Coliform	TP-BR3- RV Space #286	Water Monitoring-Routine #3
	STK1452862-1	2014-12-22	Coliform	TP-BR3- RV Space #286	Water Monitoring-Routine #3
RV Space #228	STK1430954-1	2014-02-03	Coliform	TP-BR4- RV Space #228	Water Monitoring-Routine #4
	STK1432124-1	2014-03-10	Coliform	TP-BR4- RV Space #228	Water Monitoring
	STK1432310-1	2014-03-17	Coliform	TP-BR4- RV Space #228	Water Monitoring-Routine #4
	STK1433778-1	2014-04-28	Coliform	TP-BR4- RV Space #228	Water Monitoring-Routine #4
	STK1433887-1	2014-04-29	Coliform	TP-BR4- RV Space #228	Water Monitoring-Routine #4
	STK1434699-4	2014-05-19	Coliform	TP-BR4- RV Space #228	Water Monitoring-Routine #4
	STK1435570-1	2014-06-09	Coliform	TP-BR4- RV Space #228	Water Monitoring-Routine #4
	STK1436839-4	2014-07-09	Coliform	TP-BR4- RV Space #228	Water Monitoring-Routine #4
	STK1437251-1	2014-07-21	Coliform	TP-BR4- RV Space #228	Water Monitoring-Routine #4
	STK1437376-3	2014-07-24	Coliform	TP-BR4- RV Space #228	Water Monitoring-Routine #4
	STK1438637-1	2014-08-25	Coliform	TP-BR4- RV Space #228	Water Monitoring-Routine #4
	STK1450163-1	2014-10-06	Coliform	TP-BR4- RV Space #228	Water Monitoring-Routine #4
	STK1450557-3	2014-10-13	Coliform	TP-BR4- RV Space #228	Water Monitoring-Routine #4
	STK1450677-3	2014-10-16	Coliform	TP-BR4- RV Space #228	Water Monitoring-Routine #4
	STK1451685-1	2014-11-17	Coliform	TP-BR4- RV Space #228	Water Monitoring-Routine #4
	STK1453020-1	2014-12-29	Coliform	TP-BR4- RV Space #228	Water Monitoring-Routine #4
RV Space #232	STK1433887-3	2014-04-29	Coliform	TP-BR4- RV Space #232	Water Monitoring-Routine #4
R+HS Btwn Shd 1	STK1431251-1	2014-02-10	Coliform	TP-BR5- R+HS Betwn Shed1&2	Water Monitoring-Routine #5
	STK1432753-1	2014-03-31	Coliform	TP-BR5- R+HS Betwn Shed1&2	Water Monitoring-Routine #5
	STK1434699-6	2014-05-19	Coliform	TP-BR5- R+HS Betwn Shed1&2	Water Monitoring-Routine #5
	STK1435841-1	2014-06-16	Coliform	TP-BR5- R+HS Betwn Shed1&2	Water Monitoring-Routine #5
	STK1436839-5	2014-07-09	Coliform	TP-BR5- R+HS Betwn Shed1&2	Water Monitoring-Routine #5
	STK1437376-4	2014-07-24	Coliform	TP-BR5- R+HS Betwn Shed1&2	Water Monitoring-Routine #5
	STK1438882-1	2014-09-02	Coliform	TP-BR5- R+HS Betwn Shed1&2	Water Monitoring-Routine #5
	STK1450557-4	2014-10-13	Coliform	TP-BR5- R+HS Betwn Shed1&2	Water Monitoring-Routine #5
	STK1450611-1	2014-10-15	Coliform	TP-BR5- R+HS Betwn Shed1&2	Water Monitoring-Routine #5
	STK1450677-4	2014-10-16	Coliform	TP-BR5- R+HS Betwn Shed1&2	Water Monitoring-Routine #5
	STK1451890-1	2014-11-24	Coliform	TP-BR5- R+HS Betwn Shed1&2	Water Monitoring-Routine #5
Slip 159 (Tomat	STK1430072-1	2014-01-06	Coliform	TP-BR6- Slip 159 (Tomato Shed)	Water Monitoring-Routine #6
	STK1431418-1	2014-02-17	Coliform	TP-BR6- Slip 159 (Tomato Shed)	Water Monitoring-Routine #6
	STK1432497-1	2014-03-24	Coliform	TP-BR6- Slip 159 (Tomato Shed)	Water Monitoring-Routine #6
	STK1434068-1	2014-05-05	Coliform	TP-BR6- Slip 159 (Tomato Shed)	Water Monitoring-Routine #6
	STK1434699-5	2014-05-19	Coliform	TP-BR6- Slip 159 (Tomato Shed)	Water Monitoring-Routine #6
	STK1436136-1	2014-06-23	Coliform	TP-BR6- Slip 159 (Tomato Shed)	Water Monitoring-Routine #6
	STK1436839-6	2014-07-09	Coliform	TP-BR6- Slip 159 (Tomato Shed)	Water Monitoring-Routine #6
	STK1437376-1	2014-07-24	Coliform	TP-BR6- Slip 159 (Tomato Shed)	Water Monitoring-Routine #6
	STK1437472-1	2014-07-28	Coliform	TP-BR6- Slip 159 (Tomato Shed)	Water Monitoring-Routine #6
	STK1439230-1	2014-09-08	Coliform	TP-BR6- Slip 159 (Tomato Shed)	Water Monitoring-Routine #6
	STK1450557-1	2014-10-13	Coliform	TP-BR6- Slip 159 (Tomato Shed)	Water Monitoring-Routine #6
	STK1450677-1	2014-10-16	Coliform	TP-BR6- Slip 159 (Tomato Shed)	Water Monitoring-Routine #6
	STK1450692-1	2014-10-20	Coliform	TP-BR6- Slip 159 (Tomato Shed)	Water Monitoring-Routine #6
	STK1452037-1	2014-12-01	Coliform	TP-BR6- Slip 159 (Tomato Shed)	Water Monitoring-Routine #6